



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

December 13, 2019
Subject: Creek Brook Bridge
Replacement
State WIN: 022248.00
Location: **Lovell**
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: Is Item 203.20 Common Excavation only used to achieve subgrade for roadway gravels, shoulders and side slopes?

Response: Yes, this is correct.

Question: Item 203.25 Granular Borrow shall only be used 1.5' around proposed box culvert? Note 7 on sheet says all embankment material placed below EL 382.5 shall be granular borrow. Will contractors be allowed to use excavated material for backfill? Or will granular borrow need to be used and considered incidental to the project?

Response: Any material placed outside the excavation and backfill pay limits and below EL 382.5 shall meet the requirements of underwater backfill and will be incidental to the contract.

Consider these changes and information prior to submitting your bid on **December 18, 2019**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer